

إدارة مختبر دبي المركزي  
Dubai Central Laboratory Department (DCLD)شهادة مطابقة للمنتج  
CERTIFICATE OF PRODUCT CONFORMITY

Certificate number:	CL18020574 R01	رقم الشهادة:
Issued to the Product:	Low Emitting Materials Details as per the attached Scope of Certification	تم منح الشهادة للمنتج:
Manufactured by:	ANCHOR ALLIED FACTORY L.L.C. BRANCH 3	مصنع من قبل:
Address:	P.O. Box 21152, Emirates Industrial City, Sajjah, Sharjah, UAE	العنوان:

تم تقييم المنتج وفقاً لمرجع إدارة مختبر دبي المركزي رقم (IC) DM-DCLD-RD-DP21-2001 "الأحكام العامة لنظام بلدية دبي لمنح شهادة مطابقة المنتج من قبل طرف ثالث من خلال تقييم المصنع" والأحكام الخاصة ذات الصلة، وتم الإقرار بناءً عليه بأنه مطابق للمواصفة القياسية:

The product has been assessed in accordance to DCLD Document Reference No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

2023 AL SA'FAT DUBAI GREEN BUILDING SYSTEM

وطبقاً لذلك، تفوض إدارة مختبر دبي المركزي الشركة المصنعة المذكورة أعلاه بوضع علامة المطابقة للمنتج على المنتج/المنتجات المذكورة أعلاه

Accordingly, DCLD hereby authorizes the above manufacturer to affix the DCL Product Conformity Mark on the above-mentioned product(s)

Original Issue Date:	15/04/2018	تاريخ الإصدار الأولي:
Current Issue Date:	19/07/2024	تاريخ الإصدار الحالي:
Valid until:	14/04/2025	صالحة لغاية:

MAJED AL SHAMSI  
Manager of Certification and Quality Control of Products Section  
Dubai Central Laboratory Department-Dubai Municipality

The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.

This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

OPEN-DATA

DM-DCLD-F-IC-2031 Rev 26

**DUBAI CENTRAL LABORATORY DEPARTMENT  
DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION  
FOR CERTIFICATE NO. CL18020574-REVISION 01**

**Certificate Issued To:** ANCHOR ALLIED FACTORY L.L.C. BRANCH 3  
P.O. Box 21152, Emirates Industrial City, Sajjah,  
Sharjah, UAE

**Applicable Standard Specification:** Al Sa'fat – Dubai Green Building System -2<sup>nd</sup>  
Edition

**Applicable Specific Rules:** DM-DCLD-RD-DP21-2180-(IC): Certification of  
Low Emitting Materials as per Al Sa'fat – Dubai  
Green Building System

S/N	PRODUCT DESCRIPTION	BRAND NAME	PRODUCT DETAILS
<b>THE PRODUCTS PRODUCED IN "ANCHOR ALLIED FACTORY - LLC - BRANCH 3", SHARJAH</b>			
1.	ARCHITECTURAL SEALANT	ASMACO GOLD UNIVERSAL MULTI FOAM B1 GRADE	Sealant for Specific Application VOC (Al Sa'fat DGBS limit is Max 250 g/l)
		ASMACO GOLD UNIVERSAL MULTI FOAM B2 GRADE	
		ASMACO GOLD UNIVERSAL MULTI FOAM	
		ASMACO G2100 PU FOAM*	
<b>THE PRODUCTS PRODUCED IN "ANCHOR ALLIED FACTORY - LLC", RAS AL KHAIMAH (External/Outsourced Production Facility)</b>			
1.	ONE PACK PERFORMANCE COATING (SUB-CATEGORY: 9)	ASMACOAT WP 900	Solvent Base Coatings for Interior/Exterior intermediate coatings Applications <b>(White Color)</b> (Coating - Other Types) VOC (Al Sa'fat DGBS limit is Max.500 g/l) <b>SRI</b> (Result of sample tested is $\geq 78$ )
		ASMACOAT WP 810	

## DUBAI CENTRAL LABORATORY DEPARTMENT DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME

### SCOPE OF CERTIFICATION FOR CERTIFICATE NO. CL18020574-REVISION 01

	ONE PACK PERFORMANCE COATING (SUB-CATEGORY: 9)	ASMACOAT WP 936	(See Note 4)
		ASMACOAT WP 600 (White Color)	Water Base Coatings for Exterior applications (Roof Coating)  VOC (Al Sa'fat DGBS limit is max.140g/l)  Formaldehyde < 10 mg/kg SRI (Result of sample tested is ≥ 78)  (See Note 4)
		ASMACO AMP WATERPROOFING* (White Color)	Water Base Coatings for Interior / Exterior applications (Wall, Roof, Floor)  VOC (Al Sa'fat DGBS limit is max.140g/l)  Formaldehyde < 10 mg/kg SRI (Result of sample tested is ≥ 78)  (See Note 4)
2	TWO PACK PERFORMANCE COATING * (SUB-CATEGORY: 10)	ASMACO FLOOR FC 160 CP*	Solvent Free Coatings for Interior / Exterior applications (Wall, Floor)  VOC (Al Sa'fat DGBS limit is max.140g/l)
		ASMACO FLOOR FC 150*	
		ASMACO POXY 90 FC*	
		ASMACO POXY 95*	
3	ARCHITECTURAL SEALANT	ASMACO 2670	Sealant for Specific Application  VOC (Al Sa'fat DGBS limit is Max 250 g/l)
		ASMACO GLASS	
		ASMACO FIRESTOP SILICONE SEALANT	
		ASMACO INTUMESCENT ACRYLIC SEALANT	
		ASMACO PU 90	
		NEOFLEX PU 25LM	

**DUBAI CENTRAL LABORATORY DEPARTMENT  
DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION  
FOR CERTIFICATE NO. CL18020574-REVISION 01**

	ARCHITECTURAL SEALANT	ASMACRYL 47 ASMACRYL 52 GYPROC SEALANT CRAYCOAT ACRYLIC DUCT SEALANT "Asianpaints Berger" Brand SMARTCARE UNYVERSEAL NEUTRAL "Asianpaints Berger" Brand SMARTCARE ACRYLMAX "Asianpaints Berger" Brand SMARTCARE UNYVERSEAL PU "Asianpaints Berger" Brand SMARTCARE UNYVERSEAL POLYSULPHIDE PG "Asianpaints Berger" Brand SMARTCARE UNYVERSEAL POLYSULPHIDE GG ANCHORSEAL 963 PG ANCHORSEAL 963 GG Alpha Duct Acrylic Sealant ASMACO POXY 90 FC* ASMACO POXY 95* Asmaco Crystal Clear- Classic fix*	Sealant for Specific Application  VOC (Al Sa'fat DGBS limit is Max 250 g/l)
4.	SEALANT OTHERS	ASMACO 2500 ASMACO GP ASMACO 2540 "Asianpaints Berger" Brand SMARTCARE UNYVERSEAL ANTIFUNGAL "Asianpaints Berger" Brand SMARTCARE UNYVERSEAL GP ADVANCED Asmaco 2860 structural Glazing Silicone Sealant Asmaco All in 1 Hybrid Sealant Asmacryl 55 fire stop acrylic sealant	VOC (Al Sa'fat DGBS limit is Max 420 g/l)

## DUBAI CENTRAL LABORATORY DEPARTMENT DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME

### SCOPE OF CERTIFICATION FOR CERTIFICATE NO. CL18020574-REVISION 01

		Asmaco 4400 All-weather sealant	
		ASMACO 4450 Construction & Concrete Hybrid Sealant	
		Asmaco 2650	
		S-2200 Silicone Sealant	
		Asmaco Instant Grab Adhesive sealant	
		Asmaco 2200 silicone sealant	
		Asmaco GP Fast Silicone Sealant*	
		Asmaco PU 90 SP-UAE*	
		Asmaco High Temp RTV silicone sealant*	
		Asmaco 2680 FG Silicone Sealant-UAE*	
		Asmaco 2860 Silicone Sealant*	
		Asmaco 2880 Silicone Sealant*	
		Masterseal 121 sanitary sealant	
		Masterseal 10WB gap filler sealant	
		Masterseal 123 NS sealant	
		Masterseal NP 473 U sealant	
5.	ADHESIVE-SPECIALTY APPLICATIONS	ASMACO GOLD CONTACT ADHESIVE	(Sheet Applied Rubber Lining Operations) VOC (Al Sa'fat DGBS limit is Max 850 g/l)
		Weldfix UPVC cement P 917 UPVC cement	
		Weldfix CPVC cement C 914 CPVC cement	
		Asmaco P914 UPVC cement	
		Asmaco fix P917 UPVC cement	
6.	ADHESIVE-MULTI-PURPOSE CONSTRUCTION*	ASMACO POXY 90 FC*	VOC (Al Sa'fat DGBS limit is Max 70 g/l)
		ASMACO POXY 95*	
		Asmaco PUR Glue*	

**DUBAI CENTRAL LABORATORY DEPARTMENT  
DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION  
FOR CERTIFICATE NO. CL18020574-REVISION 01**

		Asmaco all purpose Pipe Lubricant & Adhesive*	
		Asmaco Crystal Clear- Classic fix*	

- NOTE 1:** This document forms an integral part of the Certificate of Product Conformity bearing the same certificate number.
- NOTE 2:** The above product shall bear the DCLD Conformity Mark.
- NOTE 3:** As applicable, other properties in the product standard specification which were excluded in the specific rules as approved by the certification body authorized personnel are to be verified by the end user of the product (if needed).
- NOTE 4:** The above SRI value is just for information. The user (owner, contractor and/or consultant) shall be fully responsible for ensuring that the correct SRI value is followed according to the requirements of the applicable clause in the standard specification. Acceptance limit shall be as per these values for each application of the product.
- NOTE 5:** This supersedes the Scope of Certification issued on 15 April 2024 due to additional products marked with \*.

**Original Issue Date** : 15 April 2018

**Current Issue Date** : 19 July 2024

**Valid Until** : 14 April 2025



**MANAGER**

**CERTIFICATION AND QUALITY CONTROL OF PRODUCTS SECTION**